

Certificate

Registration No.: PV 50198331

Page 1

Report No.: 15036867.004

License Holder:
Pramac Swiss S.A.
Via Campagna, 19
Riazzino 6595
Switzerland

Product:
PV Module
Type:
With 72x6" poly cell:
PRAMAC LUCE MC-A xxx (xxx=250-285 in
increments of 5)
With 60x6" poly cell:
PRAMAC LUCE MC-A xxx (xxx=200-240 in
increments of 5)

Manufacturing Plant:
0001-15036867 001

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- Qualified, IEC 61215
- Safety tested,
IEC 61730
- Periodic inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants
at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or
processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 25 August 2015.

Shanghai, 07 March 2011

Certification body

Dipl.-Ing. Bernd Scheirer



TÜV Rheinland LGA Products GmbH, Tillystrasse 2, D-90431 Nürnberg
Contact: + (+49) 221 806-1371 email: cert-validity@de.tuv.com